## SafeSite® LED Linear Fixture

#### Class I Div. 2 Ordering Information

Part Number	Length	Туре	CRI	CID1	CID2	CIID1	CIID2	CIII	Voltage	Lens	ССТ	Fixture Lumens	Watt	LPW
LSD3C4MEP	4'	Sustained	75		•		•		100 - 277V AC	Clear	5000K (cool white)	7,000	85	85
LSD3C4MNP	4'	Maintained	75		•		•		100 - 277V AC	Clear	5000K (cool white)	7,000	85	85

### Class II Ordering Information

Part Number	Length	Туре	CRI	CID1	CID2	CIID1	CIID2	CIII	Voltage	Lens	CCI	Fixture Lumens	Watt	LPW
LSF3C4MEP	4′	Sustained	75			E/F/G	F/G	•	100 - 277V AC	Clear	5000K (cool white)	7,000	85	85
LSF3C4MNP	4′	Maintained	75			E/F/G	F/G	•	100 - 277V AC	Clear	5000K (cool white)	7,000	85	85

#### Notes:

For Dialight's complete list of DLC qualified products, please click this link: www.dialight.com/DLC

# Battery Back up Models - Class I, Div. 2 / Class II

	Part Number	Material	Description	Kit Includes
X .	LSXW4	6061 Aluminum	Mounting bracket Can be angled at 0°, 30°, 45°, 60° & 90°	Mounting bracket Mounting hardware
A. A.	LSXENDCAPKIT	304 Stainless Steel	Chain mount brackets	2 Mounting brackets Mounting hardware
	HZXSAFEKIT	316 Stainless Steel	Safety Cable Kit	2 Eyelets 2 53" Safety cables Mounting hardware

Part numbers listed in the above table are cool white. For neutral white models replace the 5th character with <u>N</u>. Ex. LSF3<u>C</u>4D2P becomes LSF3<u>N</u>4D2P

<sup>&</sup>lt;sup>2</sup>450 Lumens in Battery Backup mode

Expect a 10% reduction in Lumens for 80 CRI minimum fixtures

<sup>\*</sup>All lumen values are typical (tolerance +/- 10%)
\*See application note on page 6 regarding "sustained" and "maintained" battery modes