

Certificate

No: B 98 08 13332 398

TÜV
PRODUCT SERVICE

Idec Izumi Corporation

1-7-31 Nishimiyahara
Yodogawa-Ku, Osaka 532-0004
Japan

with production facilities
33644

is authorized to label the following products with the
certification mark E
as shown in the certification mark list. See also notes overleaf.

Product: Notausschalter
E-Stop Contact Block

Model: Type HW-S01, -S10, -S01R, -S10R

Parameters:

Rated Input Voltage:	600 VAC/DC
Rated Frequency:	50/60 Hz
Rated Input Current:	AC-15, DC-13
Protection Class:	Class II

License Conditions:

1. End application has installed unit in an IP20 type minimum fire enclosure.
2. End application has unit protected in the inputs and outputs with a T10A, 250V type fuse.
3. The -SXXR types cannot be used as a primary disconnect contact block.

The product meets the relevant safety requirements and was tested according to (report no.: D923855901):

IEC 947-5-1:1990

Released with the above certificate number by the certification body of TÜV PRODUCT SERVICE GMBH.

R - (B 98 07 13332 397)

Department: DANITE / MAD

Date: 08-12-98

