

CERTIFICATE

No. B 04 08 13332 034



Holder of Certificate: **Idec Izumi Corporation**

1-7-31 Nishimiyahara
Yodogawa-Ku, Osaka 532-8550
Japan



Certification Mark:



Product: **Power supply**

Switching Power Supply

The product was tested on a voluntary basis and complies with the essential requirements.
The certification mark shown above can be affixed on the product. See also notes overleaf.

Test report no.: 73505214



Date, 2004-08-02

Page 1 of 2

CERTIFICATE

No. B 04 08 13332 034



Model(s): PS5R-SF24, PS5R-SG24, PS5R-SC12
PS5R-SC24, PS5R-SD24, PS5R-SE24

Parameters:

PS5R-SC12:
Input: 100-240V ac 50/60Hz 0,9A
Output: 12V dc 2,5A SELV Output

PS5R-SC24:
Input: 100-240V ac 50/60Hz 0,9A
Output: 24V dc 1,3A SELV Output

PS5R-SD24:
Input: 100-240V ac 50/60Hz 1,7A
Output: 24V dc 2,5A SELV Output

PS5R-SE24:
Input: 100-240V ac 50/60Hz 2,3A
Output: 24V dc 3,75A SELV Output

PS5R-SF24:
Input: 100-240V ac 50/60Hz 1,8A
Output: 24V dc 5,0A SELV Output

PS5R-SG24:
Input: 100-240V ac 50/60Hz 3,5A
Output: 24V dc 10,0A SELV Output

Protection class: I
Overvoltage category: II

Remark:
When installing/inserting the equipment all requirements of the mentioned test standards must be fulfilled.

Tested according to: EN 50178:1997
EN 60950:2000

Production Facility(ies): 24200, 17406

