



Certificate of Compliance

Certificate: 2604407 (LR 35144)

Master Contract: 166730

Project: 2666251

Date Issued: October 4, 2013

Issued to: IDEC Corporation
6-64 Nishimiyahara 2-Chome
Yodogawa-Ku, Osaka 532-0004
Japan
Attention: Lanny Schuberg

The products listed below are eligible to bear the CSA Mark shown



Rowell Manipula

Issued by: Rowell Manipula

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

Relays, Series RF2S and RF2V with suffixes, open type with dust cover, 2-pole, 6A (NO), 3A (NC), resistive, 277V ac; 6A(NO), 3A (NC), resistive, 30V dc. Coil rated 5 through 125V dc.

Note: Open type devices are Certified as components only for use in other Certified equipment where the suitability of the combination is to be determined by CSA International

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 14 - Industrial Control Equipment